



CROSS SECTION

N.T.S.

GENERAL NOTES:

- 1.) THIS DETAIL SHALL APPLY TO DOWNSPOUTS ADJACENT TO HARD SURFACES WHERE SPLASH BLOCKING IS NOT PERMITTED.
- 2.) SOLID PVC PIPE SHALL EXTEND A MINIMUM OF 600mm(2'-0") BEYOND ALL HARD SURFACES.
- 3.) 100mm(4") PVC PIPE TRENCH TO BE BACKFILLED WITH 150mm(6") OF 20mm(3/4") CLEAR STONE AND LINED WITH NON-WOVEN GEOTEXTILE FILTER FABRIC.
- 4.) THE CHIEF BUILDING OFFICIAL AND CITY ENGINEER MAY APPROVE ALTERNATIVE DETAILS DEPENDING ON SITE SPECIFIC SOIL CONDITIONS AND OTHER CIRCUMSTANCES.

CITY OF WINDSOR

ENGINEERING DEPARTMENT

**DOWNSPOUT DISCHARGE
ADJACENT TO HARD SURFACING**

DR'N BY: M.L.R/A.C.	DATE: JULY, 2021
REVISION:	CH'KD BY: P.W.
CH'KD BY: P.J.U.	PASSED BY:

(Signature)
MARK WINTERTON, CITY ENGINEER

AS-562