



**THE CORPORATION OF THE CITY OF WINDSOR  
OFFICE OF THE CITY SOLICITOR**

**ALEX VUCINIC**  
**Manager of Purchasing**

**Elaine Castellan**  
**Purchasing Supervisor**

**(519) 255-6272**  
**TELEPHONE NUMBER**

**ADDENDUM NO. 5  
TENDER NO. 158-18  
2019 PELISSIER GARAGE 2 – BEAUTIFICATION PROJECT**

**January 17, 2019**

---

This addendum amends and forms part of the Tender Documents. The bidder shall insert the addendum behind the cover page of the Tender Documents.

**QUESTIONS/ANSWERS:**

1. Regarding Drawing PEL-A9 revised in addendum #4:

- a. Special-Lite will not factory install hardware for the All Fiberglass Series Fire Rated Door Types B & D. Please clarify that all hardware for Special-Lite door types A thru D can be site installed.

Answer: The City requires complete installation. The contractor is responsible to confirm with the supplier.

2. Regarding Drawing PEL-A10 revised in addendum #4:

- a. Window W1 has a glazing type noted as “Single Glazing laminated to ¼” clear wire glazing”. It is not possible to laminate anything to GPW glazing. Please clarify what is to be used as an alternate.

Answer: Revised - single pane of ¼” clear wire glazing (GPW)

- b. Window W9 has a glazing type noted as “Inside Face #2 PC9912 Std. White Translucent Ceramic Frit Silkscreened on 3/8” tempered single glazing laminated to ¼” clear wire glazing”. This type is also not possible. Please clarify what is to be used as an alternate.

Answer: Revised - the ¼” clear wire glazing pane (GPW) is to be placed against the 3/8” white translucent pane (NOT laminated) this is allowed.

3. Regarding Spec. Section 08 81 13 – GLAZING:

Can you please update the spec. to clarify and describe the new glazing combinations noted on PEL-A9 & PEL-A10 issued in addendum #4? The spec. does not correspond with the new glazing type descriptions.

Answer: Not required, per notes above

Except for the contents of this addendum, all other terms and conditions of this tender remain the same.

***END OF ADDENDUM NO. 5***

Yours truly,

**THE CORPORATION OF THE CITY OF WINDSOR**

*Elaine Castellan*

Elaine Castellan  
Purchasing Supervisor

EC/jm

---

**ADDENDUM NO. 5  
TENDER NO. 158-18  
2019 PELISSIER GARAGE 2 – BEAUTIFICATION PROJECT**

**January 17, 2019**

---

I hereby acknowledge receipt of Addendum No. 5 to the Tender No. 158-18 (3 pages).

The information contained therein is hereby noted and account of same will be taken in our tender cost.

This information was received on the \_\_\_\_\_ day of \_\_\_\_\_, 20\_\_\_\_\_.

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Name (Printed)

\_\_\_\_\_  
Company Name

**\*NOTE: You are required to acknowledge this addendum with your TENDER submission.**

**PLEASE FAX BACK TO (519) 255-9891 OR E-MAIL @ [purchasing@citywindsor.ca](mailto:purchasing@citywindsor.ca) SIGNED  
ACKNOWLEDGEMENT SHEET ASAP**

**Attn: Purchasing Department**