



**THE CORPORATION OF THE CITY OF WINDSOR  
OFFICE OF THE CITY SOLICITOR**

**ALEX VUCINIC**  
Manager of Purchasing

**Elaine Castellan**  
Purchasing Supervisor

**(519) 255-6272**  
**TELEPHONE NUMBER**

**ADDENDUM NO. 1  
TENDER NO. 143-18  
GENERATOR REPLACEMENT – FIRE APPARATUS**

**August 28, 2018**

This addendum amends and forms part of the Tender Documents. The bidder shall insert the addendum behind the cover page of the Tender Documents.

**MANDATORY SITE –MEETING ATTENDEES:**

Gas Powered Solutions Inc.  
Thermal Process Systems Inc. dba Thermecs  
Rorison Electric Limited  
Vollmer Inc.

City of Windsor:  
Brent Paisley, Windsor Fire & Rescue, Monika Grant, Facilities Department, Scott Fraser, Purchasing

**CLOSING DATE:** The closing date has been extended to, **MONDAY, SEPTEMBER 10, 2018.**

**CLARIFICATIONS:**

- Contractor is required to verify all loads.
- Contractor is to ensure all clearances required by code are adhered to.
- Contractor is responsible for any design and engineering required to complete the work. Both a hard copy and electronic copy of stamped drawings and/or reports are to be submitted at completion of project.

**QUESTIONS & ANSWERS:**

Q1 Is a Natural gas system acceptable

A. No

Q2. 347V or 600V ?

A. 600V

Q3. Is load based upon 225 Amps?

A. Yes

Q4. Is contractor responsible for utility, sewer, etc. locates?

A. Yes

Q5. Who is responsible for tree removal in enclosure area?

A. City will arrange for tree removal if necessary.

Q6. Is fencing required around genset?

A. Yes

Q7. Will you issue civil specs and drawings for the sound attenuating enclosure?

A. The City will not be issuing civil specs or drawings for the sound attenuating enclosure. Contractor is responsible for the design and installation of the sound attenuating enclosure. The enclosure must meet all regulated requirements. Stamped drawings of the enclosure shall be included as part of the submittal package”.

Q8. Will you issue a floor plan / site plan ?

A. A floor plan/site plan is not available for this building

Q9. Will there be another opportunity to visit the site for review with subtrades; if so, what date and time?

A. A second optional site visit will be permitted. Scheduled date of second visit is **Thursday, August 30<sup>th</sup>, 1:30 p.m.**

Q10. Available downtime for tie-in?

A. In addition to evening hours detailed in the tender document, work requiring power to be turned off to the building may also be completed on weekends.

**Except for the contents of this addendum, all other terms and conditions of this tender remain the same.**

**END OF ADDENDUM NO. 1**

Yours truly,

**THE CORPORATION OF THE CITY OF WINDSOR**

*Elaine Castellan*

Elaine Castellan  
Purchasing Supervisor  
EC/sf

---

**ADDENDUM NO. 1  
TENDER NO. 143-18  
GENERATOR REPLACEMENT – FIRE APPARATUS**

---

**August 28, 2018**

I hereby acknowledge receipt of Addendum No. 1 to the Tender No. 143-18 (4 pages).

The information contained therein is hereby noted and account of same will be taken in our tender cost.

This information was received on the \_\_\_\_\_ day of \_\_\_\_\_, 20\_\_\_\_.

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Name (Printed)

\_\_\_\_\_  
Company Name

**\*NOTE: You are required to acknowledge this addendum with your TENDER submission.**

**PLEASE FAX BACK TO (519) 255-9891 OR E-MAIL @ [purchasing@citywindsor.ca](mailto:purchasing@citywindsor.ca) SIGNED  
ACKNOWLEDGEMENT SHEET ASAP**

**Attn: Purchasing Department**