



**THE CORPORATION OF THE CITY OF WINDSOR
OFFICE OF THE CITY SOLICITOR**

ALEX VUCINIC
Manager of Purchasing

Elaine Castellan
Purchasing Supervisor

(519) 255-6272
TELEPHONE NUMBER

**ADDENDUM NO. 1
LED LIGHTING INSTALLATION – MIC MAC PARK (CULLEN FIELD)
RFT NO. 23-19**

February 8, 2019

This addendum amends and forms part of the Tender Documents. The Bidder shall insert the addendum behind the cover page of the Tender Documents.

QUESTIONS & ANSWERS:

Q1. Page 31; It states that all poles are to be 80' tall, however, we have two (2) poles B1 and B2 that are 90 ft. tall. This may impact spill and glare as well as uniformity on the field. Can we use our design with the two (2) 90' poles, or must all poles be 80 ft.?

Yes, two (2) 90 ft. poles, B1 and B2, can be used for the design.

Q2. Page 32; It states that a maximum Candela at 150' is to be 40,000. Do you require a candela report from Musco in the bid package?

Yes, a Candela Report should be submitted.

Except for the contents of this addendum, all other terms and conditions of this tender remain the same.

END OF ADDENDUM NO. 1

Yours truly,

THE CORPORATION OF THE CITY OF WINDSOR

Elaine Castellan

Elaine Castellan
Purchasing Supervisor

EC/sf

**ADDENDUM NO. 1
LED LIGHTING INSTALLATION – MIC MAC PARK (CULLEN FIELD)
RFT NO. 23-19**

February 8, 2019

I hereby acknowledge receipt of Addendum No. 1 to the RFT No. 23-19 (2 pages).

The information contained therein is hereby noted and account of same will be taken in our tender cost.

This information was received on the _____ day of _____, 20_____.

Signature

Name (Printed)

Company Name

***NOTE: You are required to acknowledge this addendum with your tender submission.**

**PLEASE FAX BACK TO (519) 255-9891 OR E-MAIL @ purchasing@citywindsor.ca SIGNED
ACKNOWLEDGEMENT SHEET ASAP**

Attn: Purchasing Department