



- NOTES**
- 1 ALL PREMOLDED JOINT FILLER, SHALL CONFORM TO M.T.C. FORM 1309.
 - 2 SPACING OF TYPE B TRANSVERSE CONTRACTION JOINTS SHALL NOT EXCEED 16 FEET, MIN. 12 FEET.
 - 3 WHEN A JOINT OCCURS WITHIN 5 FEET OF, OR CONTACTS A CATCH BASIN, MANHOLE, OR UTILITY VALVE STRUCTURE, SHORTEN ONE OR MORE PANELS EITHER SIDE OF OPENING TO PERMIT JOINT TO FALL ON CENTRE OF STRUCTURE.
 - 4 ANGLES BETWEEN PAVEMENT JOINTS MUST NOT BE LESS THAN 45°.
 - 5 ISOLATED AREAS FOR CATCH BASINS, MANHOLES, UTILITY VALVES ETC. TO BE INTERNALLY JOINTED USING 2" DEEP, 1/4" THICK PREMOLDED FILLER.
 - 6 ISOLATE ALL STRUCTURES, CATCH BASINS, MANHOLES, UTILITY VALVES ETC. USING FULL DEPTH, 1/2" THICK, PREMOLDED FILLER.
 - 7 ALL WORK SHALL CONFORM TO CITY OF WINDSOR STANDARD SPECIFICATION S-8.

CITY OF WINDSOR DEPARTMENT OF PUBLIC WORKS	
RURAL RESIDENTIAL CONCRETE PAVEMENT	
DRAWN BY : L. E. B.	DATE FEB. 1973
REVISION : MARCH/75	CHECKED BY: <i>[Signature]</i>
CHECKED BY: <i>[Signature]</i>	PASSED BY: <i>[Signature]</i>
<i>H. Sahm</i> COMMISSIONER OF WORKS	
AS-227	