



NOTES:

1. WHERE SHEATHING IS USED A BOND BREAKING MATERIAL IS REQUIRED BETWEEN CONCRETE AND SHEATHING.
2. O.D. IS NOT TO INCLUDE BELL.

LEGEND:

X = $\left\{ \begin{array}{l} 4'' \text{ MIN.} - 6'' \text{ MAX. (D 36'' \text{ OR LESS) } \\ 6'' \text{ MIN.} - 9'' \text{ MAX. (D 39'' \text{ TO } 60'' \text{ INCL.}) \\ 9'' \text{ MIN.} - 12'' \text{ MAX. (D 66'' \text{ OR OVER) } \end{array} \right.$

CITY OF WINDSOR DEPARTMENT OF PUBLIC WORKS	
BEDDING DETAIL FOR SEWER PIPE CL.B-2	
DR'N BY : E. STERGIU	DATE : NOV. 1975
REVISION :	CH'KD BY :
CH'KD BY: <i>EM</i>	PASSED BY: <i>BA</i>
<i>H. Payne</i> COMMISSIONER OF WORKS	AS-310C